



Commercial Solar PV System Application Packet

A building permit, an electrical permit, and plan review are required for all solar photovoltaic (PV) system installations. An additional permit may be needed if structural reinforcement is required to be added to the building for mounting a solar photovoltaic (PV) system to it, or if a separate contractor is constructing the footing and piers for ground mounted solar.

Minnesota Building Code Section provides requirements for solar energy systems. A Minnesota licensed architect may be helpful in the planning and creating drawings and compiling permit submittal materials for commercial solar projects. A Minnesota licensed structural engineer will be required to design the support system for the solar equipment, whether on a building or ground-mounted. In addition to Section 3111 of the Minnesota Building Code, solar PV installations must comply with the Minnesota State Fire Code and the Minnesota Electrical Code

Rooftop-Mounted PV Installations - *Submit the following:*

- Fully completed building permit application** (*included in this packet*)
- Site Plan (see sample attached)**
 - All buildings shown & dimensioned to each other & property lines
- PV Placement Plan (see sample attached)**
 - Roof plan - PV placement shown with roof access pathways, landing points and setbacks shown
- Manufacturer's Instructions, Labeling & Instructions**
 - Mounting & Fastening Information – Data Sheet – Line Diagram – Labeling Information – Specification Sheet – Rapid Shut Down
- Roof Analysis & Plans**

Roof structures require analysis by a Minnesota licensed structural engineer and submittal of:

 - Construction plans showing the roof structure and any modifications required and installation of the solar equipment on the structure, **or**
 - A letter from the engineer describing the roof and the modifications required.
 - Cross section drawing that identifies rafter size, spacing and span dimension and approximate roof slope and panel angle, unless flush-mounted.
 - Specification of style, diameter, length of embedment of bolts (i.e., Simpson ¼" dia. SDS wood screws or equiv., 3" embedment into framing, blocking, or bracing).
- Fully completed application for an electrical permit and the following information:**
<form-electrical-permit-application-73.pdf> (duluthmn.gov)
 - Line diagram (see sample attached)
 - Manufacturer's install/data sheet
 - Site plan/diagram (see sample attached)

Ground-Mounted PV Installations- *Submit the following:*

- Fully completed application for a building permit** (*included in this packet*)
- Site Plan**
 - All buildings & PV arrays shown & dimensioned to each other & property lines. This must meet UDC setbacks.
 - Ground mounted require a clear brush free area of 10 feet surrounding the arrays
 - Ground Mounted arrays are subject to fire separation distances
- Foundations & connection details for PV arrays – stamped & signed by a Minnesota Structural Engineer**
 - Depth and size of foundation with connection detail between the PV array racking system and the foundation
- Manufacturer’s Instructions, Labeling & Information**
 - Mounting & Fastening Information – Data Sheet – Line Diagram – Labeling Information – Specification Sheet – Racking – Rapid Shut Down
- Engineered Plans**
 - Construction plans showing foundation structure
 - Specification of style, diameter, length of embedment for reinforcing steel & elements which connect the foundation to the array
- Fully completed application for an electrical permit and the following information:**
[form-electrical-permit-application-73.pdf \(duluthmn.gov\)](https://duluthmn.gov/form-electrical-permit-application-73.pdf)
 - Line diagram
 - Manufacturer’s install/data sheet
 - Site plan/diagram

Fees

Building permit and electrical permit fees are based on the valuation of the work, including materials and labor. The fee schedule for the city of Duluth is available at: [handout-fee-schedule-for-permits-139.pdf \(duluthmn.gov\)](https://duluthmn.gov/handout-fee-schedule-for-permits-139.pdf)

Submitting Permit Applications and Plans

Contractors registered with Construction Services & Inspections can submit electrical permit applications online via eTRAKIT: <https://duluthmn.gov/csi/permits-applications/apply-on-paper-or-online/>
Required documents must be provided via the upload function to make a complete application for review. Contact Construction Services & Inspections at 218-730-5240 or permittingservices@duluthmn.gov to register to use eTRAKIT.

Building permit application for alterations related to PV installations are not currently available online. Contact the Construction Services & Inspections at 218-730-5240 or permittingservices@duluthmn.gov.

Contractor licensing regulations information is available at Minnesota Department of Labor and Industries website:

<https://secure.doli.state.mn.us/lookup/licensing.aspx>



Doc 332-vA052021-0221

Commercial and 3+ Multi-family Plan Review & Building Permit Application

Complete All Items and the Checklist

Project Name		Application Date	
Site Address		Parcel ID Number	
Legal Description: Subdivision, Lot & Block or other description			
Applicant Name		Applicant is: <input type="checkbox"/> Owner <input type="checkbox"/> Contractor <input type="checkbox"/> Owner's Agent	
Contractor license #:			
Applicant Address		City	State Zip
Applicant Email (REQUIRED)		Applicant Phone (REQUIRED)	
Owner Name			
Owner Address		City	State Zip
Owner Email (REQUIRED)		Owner Phone (REQUIRED)	
Detailed Description of proposed work: <input type="checkbox"/> Residential (1 or 2 Family or Townhouse) <input type="checkbox"/> Multi-family Residential <input type="checkbox"/> Commercial			
Check Applicable: <input type="checkbox"/> Interior Remodel w/ Change of Use <input type="checkbox"/> Interior Remodel No Change of Use <input type="checkbox"/> Demolition			
<input type="checkbox"/> New Building <input type="checkbox"/> Addition <input type="checkbox"/> Sitework/Foundation Only <input type="checkbox"/> Other			
Project Valuation. Include materials and labor for all work:			
Permit Fee:	Plan Review Fee:	State Surcharge:	Total Enclosed:
Design Professional (Architect or Engineer) or Plan Preparer Name			
Design Professional or Plan Preparer Address		City	State Zip
Design Professional or Plan Preparer Email (REQUIRED)		Phone (REQUIRED)	
Commercial Multi-Family	Occupancy Use Group(s) circle: A B E F H I M R S U		Sprinklered? <input type="checkbox"/> No <input type="checkbox"/> NFPA 13 <input type="checkbox"/> NFPA 13 R
	Type(s) of Construction (circle): IA IB IIA IIB IIIA IIIB IV VA VB		Food Service Facility? <input type="checkbox"/> No <input type="checkbox"/> Yes
Does the project site or any area to be disturbed by construction contain wetlands?			<input type="checkbox"/> No <input type="checkbox"/> Yes
I do hereby make application for a building permit. The application and accompanying documents are complete and accurate. Work shall be consistent with the plans and information provided with the permit application and shall comply with applicable codes, ordinances and laws and conditions of approval. Work shall not begin until a building permit has been issued.			Applicant's Signature (REQUIRED)
I am the owner of the property described herein and I authorize the submittal of a permit application for the work described here and on accompanying plans, specifications, and other construction documents.			Owner's Signature (REQUIRED)

Office Use Zone District: Stormwater Zone: Special Approvals:
LUTech:





Samples for Solar PV System Submittals

Data Sheet - Line Diagram - Site Plan – Array Layout - Labeling Information - Specification Sheet
Sample Manufacturer’s Installation/Data Sheet

APS YC500A-K Microinverter Datasheet

INPUT DATA (DC)

Maximum Input Voltage	55V
Maximum Input Current	24A

OUTPUT DATA (AC)

Rated Output Power	500W
Maximum Output Current - 240V	2.08A
Maximum Output Current - 208V	2.4A
Nominal Output Voltage/Range - 240V	211-264V*
Nominal Output Voltage/Range - 208V	183-233V*
Nominal Output Frequency/Range	60Hz / 59.3-60.5Hz*
Power Factor	>0.99
Total Harmonic Distortion	<3%
Maximum Units Per Branch	7 per 20A / 9 per 25A breaker

EFFICIENCY

Peak Efficiency	95.5%
CEC Weighted Efficiency	94.5%
Nominal MPP Tracking Efficiency	99.0%

MECHANICAL DATA

Storage Temperature Range	-40°F to +185°F (-40°C to +85°C)
Operating Temperature Range (Ambient)	-40°F to +149°F (-40°C to +65°C)
Operating Temperature Range (Internal)	-40°F to +185°F (-40°C to +85°C)
Dimensions (WxHxD) inches	7.9" x 6.3" x 1.1"
Dimensions (WxHxD) mm	200mm x 160mm x 29mm
Weight	5.5 lbs (2.5kg)
Enclosure Rating	NEMA 3R
Cooling	Natural Convection

FEATURES & COMPLIANCE

Communication	Power line
Design Lifetime	25 years
Emissions & Immunity (EMC) Compliance	FCC PART 15, ANSI C63.4 2003, ICES-003
Safety Class Compliance	UL 1741 , CSA C22.2, No. 107.1-01 Text
Grid Connection Compliance	IEEE 1547

* Programmable per customer and utility requirements
All settings UL approved

09.30.2013 © All Rights Reserved

1015 Hostmark St., Suite 104, Poulsbo, WA 98370 | 206.855.5100 | APSAmerica.com




duluthmn.gov/csi | 218-730-5240 | permittingservices@duluthmn.gov



Sample Line Diagram

NEW SERVICE PANEL 100A METER BASE, WITH EXISTING 100A MAIN PANEL INSIDE THE HOUSE.



MAIN PANEL LOCATED INSIDE THE HOME
TOTAL PV GRID AC OUTPUT : 40A
PV SOLAR INTERCONNECTION VIA SUPPLY SIDE TAP, INSIDE NEW
100A METER BASE OUTSIDE.

ALL ELECTRICAL WILL COMPLY WITH NEC CODE, STATE AND
LOCAL JURISDICTION

NOTES:

FOR MORE INFORMATION / ELECTRICAL NOTES REFER TO PAGE 10 OF THE SUBMITTALS. SOLID #8 AWG COPPER GROUND WIRE TO EXTEND FROM EACH ROOF J-BOX AND CONNECT TO EACH ROW OF RAILS VIA A TIN-PLATED COPPER GROUND LUG THAT IS LISTED FOR OUTDOOR USE. CHANGES ON STRING MIGHT CHANGE, DEPENDING ON INSTALLATION, BUT WILL BE KEPT IN ACCORDANCE WITH THE SUBMITTALS.


CONDUCTORS PER SPECS SHEET.

ALL WIRING MUST BE PROPERLY SUPPORTED BY DEVICES OR MECHANICAL MEANS DESIGNED AND LISTED FOR SUCH USE AND WIRING MUST BE PERMANENTLY AND COMPLETELY FIELD OFF OF THE ROOF SURFACE. SEE NEC 110.2, 110.5(A), 110.3(D), AND 300.4.

Sample Site Plan




HOME TOTAL ROOF AREA:
2,523.15 sqft.












Sample Array Layout

ROOF INFORMATION			
ROOF SECTIONS	# OF MODULES	TILT	AZIMUTH
A	18	40°	270°




2020 NEC Labeling Requirements




Section	Location of Label	Label Text and Appearance	Section	Location of Label	Label Text and Appearance
690.54	All interactive system(s) points of interconnection with other sources shall be marked at an accessible location at the disconnecting means as a power source and with the rated ac output current and the nominal operating ac voltage.	PHOTOVOLTAIC AC DISCONNECT MAXIMUM AC OPERATING CURRENT: NOMINAL OPERATING AC VOLTAGE:	705.12	Permanent warning labels shall be applied to distribution equipment	
690.56(B) 690.4(D) 705.10 705.12	A permanent plaque or directory, denoting all electric power sources on or in the premises, shall be installed at each service equipment location and at locations of all electric power production sources capable of being interconnected.		705.12	A permanent warning label shall be applied to the distribution equipment adjacent to the back-fed breaker from the inverter.	
690.13(B)	Each PV system disconnecting means shall plainly indicate whether in the open (off) or closed (on) position and be permanently marked: "PV SYSTEM DISCONNECT" Or equivalent.	MAIN PHOTOVOLTAIC SYSTEM DISCONNECT PHOTOVOLTAIC DC DISCONNECT PHOTOVOLTAIC AC DISCONNECT 	690.56 (C) Buildings with Rapid Shutdown PV systems shall have permanent labels as described in 690.56(C)(1) through (C)(2)	(1)(a) For PV systems that shut down the array and conductors leaving the array: The title "SOLAR PV SYSTEM IS EQUIPPED WITH RAPID SHUTDOWN" shall utilize capitalized characters with a minimum height of 3/8 in. in black on yellow background, and the remaining characters shall be capitalized with a minimum height of 3/16 in. in black on white background. (2) A rapid shutdown switch shall have a label located on or no more than 3 ft from the switch that includes this wording. The label shall be reflective, with all letters capitalized and having a minimum height of 3/8 in., in white on red background.	 
690.53	A permanent label for the direct-current PV power source indicating the information specified in (1) through (3) shall be provided by the installer at the PV disconnecting means.				
690.31(D)(2)	The following wiring methods and enclosures that contain PV power source conductors shall be marked: (1) Exposed raceways, cable trays, and other wiring methods (2) Covers or enclosures of pull boxes and junction boxes (3) Conduit bodies in which any of the available conduit openings are unused				
690.13(B) 690.15	Where all terminals of the disconnecting means may be energized in the open position, a warning sign shall be mounted on or adjacent to the disconnecting means.			The labels in 690.56(C) shall include a simple diagram of a building with a roof. Buildings with PV systems shall have a permanent label located at each service equipment location to which the PV systems are connected or at an approved readily visible location and shall indicate the location of rapid shutdown initiation devices. (1) Buildings with More Than One Rapid Shutdown Type. For buildings that have PV systems with more than one rapid shutdown type or PV systems with no rapid shutdown, a detailed plan view diagram of the roof shall be provided showing each different PV system with a dotted line around areas that remain energized after rapid shutdown is initiated.	

RAIS® XT-A PV Module 410W_p

Typical IV Curve: RAIS® XT-A 410W_p PV Module



Module Dimensions



Patents Pending
 © tenKsolar, Inc. 2013 All rights reserved
 XTAR081613EN

Application Options	
Direct Grid Connect Inverters	
Battery Only Systems	
Hybrid Inverters	

Specifications	
Power Output at STC (Pmax)	410W _p
Power Tolerance	+/- 3%
Cell Type	Polycrystalline Silicon
Number of Cells	192 Half Cells
Glass	3.2mm Tempered Glass
Maximum Current Output	9.1A
Maximum Series Fuse Rating	80A
DC Voltage Output	35V Minimum / 57V Maximum
Ground Fault Detect	Integrated (Compatible w/ Inverter GFDD)
Internal Ground Fault Limit	500 mA
Frame Size (not including optional extensions)	77.4" x 51" (1979mm x 1295mm)
Frame / Background	Silver / White
Backsheet Material	PET Covered Aluminum
Bypass Diodes	None
Ambient Operating Temperature Range	-40°F to 185°F (-40°C to 85°C)
Module NOCT (Nominal Operating Cell Temperature)	109°F (43°C)
Temperature Coefficient	-0.46% / °C
Static Load Capacity	50 psf / 2400 Pa
Hail Resistance	Direct 1" impact at 52mph (84kph)
Weight	71 lbs (32.2 kgs)
Certifications	UL 1703/UL 1741 IEC 61215 EN 61730
Warranty	12 Year Limited Product Warranty, 25 Year Linear Power Warranty: 3% Power Degradation First Year; 0.2% Linear Degradation per year after First Year

Shipping Information	
Max Quantity per Pallet	23
Pallet Dimensions	82 W x 55" D (1.4m x 2.1m)
Fully Loaded Pallet Weight	1735 lbs (787 kg)

Specifications and design are subject to change without notice.
 Read operating instructions carefully before using this product.

