Purchasing Division
Finance Department

Room 120
411 West First Street
Duluth, Minnesota 55802

218-730-5340
purchasing@duluthmn.gov

Addendum 1
Solicitation 24-99655
2025 Street Preservation Project (2194)

This addendum serves to notify all bidders of the following changes to the solicitation documents:

1. CHANGES TO RFP

PROJECT OVERVIEW AND BACKGROUND

Streets that need to be designed to State Aid Standards:

London Road
Observation Road
Maple Grove Road
Anderson Road

3f. Add language:

The Reclaim streets shall have borings done to a maximum depth of 2 LF. Mill and overlays shall be cored to determine pavement thickness above subgrade or concrete pavement. Consultant shall provide a boring Log Report with boring number, surface elevation, depth to bottom of pavements, depth to bottom of granular fill, depth to top of native soils and gradation results. Assume all borings on reclaims shall have a gradation done. All boring locations will be shown on the construction plans with a boring/core number and a bituminous pavement thickness on all streets. See plan example. Consultant shall produce an exhibit to show proposed boring locations to avoid utilities and if a modified frequency is proposed. Consult with Project Engineer beforehand.

Storm sewer work will not require additional or deeper borings. During plan/specification production it will be conveyed that all utility trenches will be backfilled with imported materials with no native backfill. (SP-23, Option C in City of Duluth 2019 SPECIAL PROVISIONS template).

3h.

Add Language:

Assume 33,000 LF of storm which includes all the mains as well as leads to CB's of varying

sizes. All pipes and structures must be cleaned before televising. Also assume 250 Catch Basins and 275 Storm and Sanitary manholes. Any collapsed pipes or structures that can't be televised must be brought immediately to the City's attention during televising. The bid for the televising shall be on a per foot basis as modification to quantities will occur.

Please acknowledge receipt of this Addendum 1 by including this addendum in the technical proposal. Failure to acknowledge this addendum may disqualify your bid.

Posted: August 30 2024