Purchasing Division
Finance Department

Room 120
411 West First Street
Duluth, Minnesota 55802

218-730-5340
purchasing@duluthmn.gov

Addendum No. 5
Solicitation 26-99071
Palm Street Smart Pond

This addendum serves to notify all bidders of the following changes to the solicitation documents:

GENERAL

1. Descriptions of changes to drawings are for reference only and provide only a general overview of changes made. It is the Contractor's responsibility to fully assess and provide the specific requirements of the Work on all Plan sheets regardless of the description of sheet change(s) provided herein.

CONTRACTOR QUESTIONS

1. **Question:** Please confirm that coir fiber matting is to be installed on 3:1 slopes or greater, and they are to be installed using live stakes following the percentages per restoration zone on sheet LA03. If so, for pricing consistency, please confirm the square yardage of 3:1 (or greater) slopes.
   Answer: Coir matting is not required since rolled erosion prevention is included for sloped areas and paid for with a separate bid item.

2. **Question:** Please verify that the shrubs and trees on the species list on sheet no. LA03 are to be included in the 4" pot item that is incidental in the restoration zones and that they are to be in 4" pots.
   Answer: Correct, the plugs shall be 4" pots.

3. **Question:** The restoration zone planting note #8 on sheet LA03 refers to L501. Where is L501 located?
   Answer: L501 is no longed in the set. This note can be ignored.

Please acknowledge receipt of this Addendum by checking the acknowledgement box within the www.bidexpress.com solicitation.

Posted: **February 9, 2026**