Purchasing Division
Finance Department

Room 120
411 West First Street
Duluth, Minnesota 55802

218-730-5340
purchasing@duluthmn.gov

Addendum 1
Solicitation 24-99591
RFP For Eng Svcs For Lead Water Service Replacements London Road LSLR

This addendum serves to notify all bidders of the following changes to the solicitation documents:

The following is added to the **Scope of Services**:

g. MnDOT completed a Phase II study of the London Road project corridor and identified areas of potential contamination that are in the vicinity of the planned LSLR work. The selected Consultant will coordinate with the City's environmental engineer (hired through a separate consultant contract with the City) throughout the project design to evaluate the potential for contaminated soils within the limits of the planned LSLR work. The City's environmental engineer will be responsible for preparing environmental project plans, special provisions, a Response Action Plan / Construction Contingency Plan (RAP/CCP) and other project documentation as needed for project review / approval with regulatory agencies. The Consultant should anticipate time and effort to coordinate with the environmental engineering and incorporate the environmental plans, special provisions, and supporting documents in its design submittals and final plans.

The following revision is made to the **Cost Proposal Contents** section:

The seventh bulleted item in the "Cost Proposal Contents" section (page 14) should refer to "Appendix B" for the purposes of this RFP.

Responses to Questions:

Question: Will the design for the service replacements be open cut installation or trenchless or both? If trenchless, does the City or MnDOT have a Geotech report they can share for the area? Or do we need to include a geotechnical sub?

Response: The installations are anticipated to be trenchless – the consultant is expected to review available information (water and sewer plats, historic plans, MnDOT geotechnical information, etc.) to determine the likely or known presence of bedrock in the vicinity of the service and to so indicate in the Plans. Consultants should not include geotechnical services in the proposal.

Please acknowledge receipt of this Addendum by including a copy of it with your proposal. The pages included will not count toward any page limitation, if any, identified in the RFP.

Posted: **7/29/24**