Purchasing Division
Finance Department

Room 120
411 West First Street
Duluth, Minnesota 55802

218-730-5340
purchasing@duluthmn.gov

Addendum 3
Solicitation 25-99414
6th Avenue East Reconditioning and Lead Water Service Replacement (High Priority Sites 100-118)

This addendum serves to notify all bidders of the following changes to the solicitation documents:

QUESTIONS: The following questions were asked and are answered below in *italics*.

1) Is the mainline paving item to be SPWEA330F or SPWEA340F?
   a) *Asphalt paving mixture is to be SPWEA340F*
2) Is SPWEA340B acceptable to be used for the Bituminous Mixture for Patching?
   a) *(with patching to occur after milling but before the underseal, it would make sense to use the most commonly available mix, SPWEA340B)*
   SPWEA340B will be allowed if patching occurs before the underseal.

Please acknowledge receipt of this Addendum by checking the acknowledgement box within the www.bidexpress.com solicitation.

Posted: **5/13/25**