Purchasing Division
Finance Department

Room 120
411 West First Street
Duluth, Minnesota 55802

218-730-5340
purchasing@duluthmn.gov

Addendum No. 4
Solicitation 26-99071
Palm Street Smart Pond

This addendum serves to notify all bidders of the following changes to the solicitation documents:

GENERAL

1. Descriptions of changes to drawings are for reference only and provide only a general overview of changes made. It is the Contractor's responsibility to fully assess and provide the specific requirements of the Work on all Plan sheets regardless of the description of sheet change(s) provided herein.

BID FORM

There are no changes to the bid form in this addendum.

DRAWINGS

There are no changes to the drawings in this addendum.

SPECIFICATIONS

There are no changes to the specifications in this addendum.

CONTRACTOR QUESTIONS

1. **Question:** Please clarify post and rail size for the fence.
   Answer: Posts shall be 3" (ID = 3.07", OD = 3.50"), rails shall be 2" (ID = 2.07", OD = 2.38")

2. **Question:** Will Flexamat be allowed for the Articulated Block Mat – Open Cell Type A?
   Answer: The block mat must create a flat surface so sediment deposits can be easily scraped off when maintaining the facility. The Flexamat product does not meet this requirement.

3. **Question:** Is the City hiring special inspection/testing services for this project?
   Answer: Yes, special inspection and testing will be provided by others, including material testing and testing of excavated materials for contamination.

Please acknowledge receipt of this Addendum by checking the acknowledgement box within the www.bidexpress.com solicitation.

Posted: **February 6, 2026**