Purchasing Division
Finance Department

Room 120
411 West First Street
Duluth, Minnesota 55802

218-730-5340
purchasing@duluthmn.gov

Addendum 2
Solicitation 24-4404
Runway 27 PAPI Replacement

This addendum serves to notify all bidders of the following changes to the solicitation documents:

Please see the attached documents.

Please acknowledge receipt of this Addendum by checking the acknowledgement box within the www.bidexpress.com solicitation.

Posted: **2/6/2024**

DOCUMENT 00 00 12

ADDENDUM NO. 2
February 6, 2024

Runway 27 Precision Approach Path Indicator (PAPI) Replacement
Duluth International Airport (DLH)
Duluth, Minnesota
City of Duluth No. 24-4404
AIP No. 3-27-0024-
SP No. A6901-
SEH No. DULAI 175696

From: Short Elliott Hendrickson Inc.
3535 Vadnais Center Drive
St. Paul, MN 55110-3507
651.490.2000

To: Document Holders

DOCUMENT HOLDERS on the above-named project are hereby notified that this document shall be appended to, take precedence over and become part of the original bidding documents dated January 18, 2024 and Addendum No. 1 dated February 2, 2024 for this work. Bids submitted for the construction of this work shall conform to this document.

This addendum consists of the revised drawing as listed below.

Changes to Drawings:

1. Drawing E-502 – Electrical Details 2: PAPI Light Housing Elevation detail is revised to reflect an 84” concrete footing depth for the PAPI light unit.

Attachments:
None

Note: Receipt of this Addendum No. 2, dated February 6, 2024 shall be acknowledged on BidExpress. Failure to do so will not allow Bidder to submit Bid.

END OF ADDENDUM